

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Powercom Ltd. 88 Avshalom Gisin Street Petach-Tikva Israel
Measuring instrument	A static Active Electrical Energy Meter Type : PCR423 Manufacturer's mark or name : Powercom Reference voltage : 3x220/380 V ... 3x240/415 V Reference current : 5 A ... 20 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10730 revision 1; - Documentation folder T10730-2.
Valid until	8 December 2025
Remark	This revision replaces the earlier version, including its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
8 August 2018


C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Reproduction of the complete
document only is permitted.