

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Inepro Metering BV Pondweg 7 2153 PK Nieuw Vennepe The Netherlands
Measuring instrument	A static Active Electrical Energy Meter Type : DZT6252 or KDK3-80AM-41 Manufacturer's mark or name : Inepro Reference voltage : 3x230/400 V Reference current : 5 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -25 °C / +55 °C Further properties are described in the annexes: - Description T10748 revision 2; - Documentation folder T10748-3.
Valid until	21 December 2025
Remark	This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
29 June 2018



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at
<http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.