


Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	SIEMENS Ltd., China 27F, No. 7 Wangjing Zhonghuan Nanlu, Chaoyang District Beijing 100102 China
Authorised representative	Smart Metering Solutions (Changsha) Co. Ltd 468# West Tongzipo Road Yuelu District, Changsha China
Measuring instrument	A static Active Electrical Energy Meter Type : GM300 Manufacturer's mark or name : Siemens Reference voltage : 3x57,7/100V – 3x240/415 V 3x100 V – 3x120V Reference current : 1 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network - three-phase three-wire network Accuracy class : C or B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10751 revision 0; - Documentation folder T10751-1.
Valid until	6 May 2026

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
6 May 2016



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).

Reproduction of the complete document only is permitted.