

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis + Gyr A.E.  
78th km National Road Athens-Corinth  
GR-201 00 Corinth  
Greece

Measuring instrument **A static Active Electrical Energy Meter**  
Type : E350s2 single phase (5271)  
Type ZCF1....s2

Manufacturer's mark or name : Landis + Gyr

Reference voltage : 230 V and 127 V (B2)  
230 V (SMR5)

Reference current : 5, 10, 15 or 20 A (B2)  
5, 10 or 15 A (SMR5)

Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network

Accuracy class : A or B (B2)  
A (SMR5)

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10838 revision 3;
- Documentation folder T10838-1.

Valid until 23 November 2027

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
19 April 2019

  
C. Oosterman  
Head Certification Board