


Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Landis+Gyr Ltd 1 Lysander Drive Northfields Industrial Estate Market Deeping PE6 8FB Peterborough United Kingdom
Measuring instrument	A static Active Electrical Energy Meter Type : E150 5246C Manufacturer's mark or name : Landis+Gyr Reference voltage : 230 V Reference current : 20 A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10851 revision 0; - Documentation folder T10851-1.
Valid until	9 December 2026

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
9 December 2016



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Reproduction of the complete document only is permitted.