

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity modules mentioned in article 17 of Directive 2014/32/EU, after  
having established that the Measuring instrument meets the applicable  
requirements of Directive 2014/32/EU, to:

Manufacturer Itron – Ganz Meter Company Ltd.  
Tancsics Mihály 11  
H-2100 Gödöllő  
Hungary

Measuring instrument A static **Active Electrical Energy Meter**

Type : A100

Manufacturer's mark or name : Itron

Reference voltage : 120 - 240 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network

Accuracy class : A or B


Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
– Description T10882 revision 0;  
– Documentation folder T10882-1.

Valid until 9 December 2026

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
9 December 2016



C. Oosterman  
Head Certification Board