

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Itron Indonesia - PT Mecoindo
EJIP Plot 6B-2, Lemah Abang
17550 Bekasi, Jawa Barat
Indonesia

Measuring instrument A static **Active Electrical Energy Meter**

Type	:	EM512 TYPE 700 JV1
Manufacturer's mark or name	:	Itron
Reference voltage	:	220, 230 or 240 V
Reference current	:	5 A
Destined for the measurement of	:	electrical energy, in a - single-phase two-wire network
Accuracy class	:	B
Environment classes	:	M1 / E2
Temperature range	:	-25 °C / +55 °C

- Further properties are described in the annexes:
- Description T10940 revision 2;
 - Documentation folder T10940-2.

Valid until 20 February 2027

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
17 February 2022

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.