

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Applicant Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Manufacturer Landis+Gyr
78 km National Road Athens
GR-20100 Corinth
Greece

Measuring instrument A static **Active Electrical Energy Meter**

Type : E360-CM3D...

Manufacturer's mark or name : Landis+Gyr

Reference voltage : 3x230/400 V

Reference current : 5 A or 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -25 °C / +55°C

Further properties are described in the annexes:

- Description T11142 revision 8;
- Documentation folder T11142-5.

Valid until 7 February 2028

Remark This revision replaces the earlier versions, excluding its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
24 March 2021

Certification Board