

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis + Gyr A.E.
78th km National Road Athens-Corinth
GR-201 00, Corinth
Greece

Measuring instrument A static **Active Electrical Energy Meter**

Type : E450 ZMXi3x0CP S3 (5363A&B)
Manufacturer's mark or name : Landis + Gyr
Reference voltage : 3x220/380 V ... 3x240/415 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : A or B
Environment classes : M2 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T11171 revision 3;
- Documentation folder T11171-2.

Valid until 1 September 2027

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
14 February 2019


C. Oosterman
Head Certification Board