

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Inepro Metering BV  
Pondweg 7  
2153 PK Nieuw Vennep  
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**  
Type : 0318  
Manufacturer's mark or name : Inepro  
Reference voltage : 3x230/400 V  
Reference current : 5 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
– Description T11234 revision 3;  
– Documentation folder T11234-3.

Valid until 28 May 2028

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
4 April 2023

Certification Board