

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer NRKsM
Pondweg 7
2153 PK Nieuw-Vennep
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : Ex9EMS 1P 2M 100A 1T, Ex9EMS 1P 2M 100A 2T, Ex9EMS 1P 2M 100A MB 2T and Ex9EMS 1P 2M 100A MO 2T

Manufacturer's mark or name : NRKsM

Reference voltage : 230 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11259 revision 1;
- Documentation folder T11259-2.

Valid until 19 January 2028

Initially issued 19 January 2018

Remark This revision replaces the earlier version, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
13 July 2023

Certification Board