

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the Measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer SE1P  
Pondweg 7  
2153 PK Nieuw-Vennep  
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type	: iEM2055
Manufacturer's mark or name	: SE1P
Reference voltage	: 230 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M1 / E2
Temperature range	: -25 °C / +55 °C

Further properties are described in the annexes:  
– Description T11299 revision 4;  
– Documentation folder T11299-3.

Valid until 13 April 2028

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

**NMI Certin B.V., Notified Body number 0122**  
13 July 2021

Certification Board

**NMI Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.