

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Rayleigh Instruments Limited
Raytel House, Cutlers Road,
South Woodham Ferrers,
Chelmsford, Essex CM3 5WA
United Kingdom

Measuring instrument A static **Active Electrical Energy Meter**

Type	:	RI-D175-C, RI-D175-MB, RI-D20M-P
Manufacturer's mark or name	:	Rayleigh Instruments Limited
Reference voltage	:	230 V
Reference current	:	5 A
Destined for the measurement of	:	electrical energy, in a - single-phase two-wire network
Accuracy class	:	A or B
Environment classes	:	M1 / E2
Temperature range	:	-25 °C / +55 °C

Further properties are described in the annexes:
– Description T11307 revision 1;
– Documentation folder T11307-2.

Valid until 28 May 2028

Issuing Authority

NMI Certin B.V., Notified Body number 0122
19 February 2019


C. Oosterman
Head Certification Board