

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer Gridspertise S.r.L
Via Robattino 54
20134 Milano
Italia

Measuring instrument A static **Active Electrical Energy Meter**
Type : GESIS
Manufacturer's mark or name : Gridspertise
Reference voltage : 3x230/400 V
3x127/220 ... 3x230/400 V
Reference current : 1 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
Accuracy class : B or A
Environment classes : M1 / E2
Temperature range : -25 °C / +55 °C

Further properties are described in the annexes;
– Description T11471 revision 22;
– Documentation folder T11471-8.

Valid until 19 December 2028

Initially issued 19 December 2018

Remark This revision replaces the previous versions, except its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
6 February 2024

Certification Board