

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr
78km National Road Athens
Corinth GR-20100
Greece

Authorised representative Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument A static **Active Electrical Energy Meter**
Type : E360 - AD2D...(S1)
Manufacturer's mark or name : Landis+Gyr
Reference voltage : 230V
Reference current : 5A or 10A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : B or A
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
– Description T11548 revision 22;
– Documentation folder T11548-3.

Initially issued 26 August 2019

Valid until 26 August 2029

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
14 February 2024

Certification Board