

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer ALLEGRA Trocknungstechnik Vertriebs GmbH
Berliner Allee 303
D-13088 Berlin
Germany

Measuring instrument A static **Active Electrical Energy Meter**

Type	: PH10
Manufacturer's mark or name	: Allegra
Reference voltage	: 230 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M1 / E2
Temperature range	: -25 °C / +55 °C

Further properties are described in the annexes:
– Description T11594 revision 1;
– Documentation folder T11594-2.

Initial issue 27 August 2019

Valid until 27 August 2029

Remark This revision replaces the previous version, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
23 January 2024

Certification Board