

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer ITRON  
1 avenue des temps modernes  
ZI du bernais B.P 23  
86361 Chasseneuil du Poitou  
France

Measuring instrument A static **Active Electrical Energy Meter**

Type : ITE414L3B2  
Manufacturer's mark or name : ITRON  
Reference voltage : 3x230/400 V  
Reference current : 10 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
Accuracy class : A or B  
Environment classes : M1 / E2  
Temperature range : -25 °C / +55 °C

Further properties are described in the annexes:  
- Description T11760 revision 3;  
- Documentation folder T11760-4.

Valid until 30 December 2029

Initially issued 30 December 2019

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
20 October 2023

Certification Board