

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Elster Rometrics SRL
Timisoara Airport Park
DJ691 km8+775m
307210 Giarmata
Romania

Measuring instrument A static **Active Electrical Energy Meter**

Type	: AS3000G or AS3500G
Manufacturer's mark	: Elster or Honeywell
Reference voltage	: 3x220/380V or 3x220V 3x230/400V or 3x230V 3x240/415V or 3x240V 3x100/173V or 3x100V 3x110/190V or 3x110V 3x120/208V or 3x120V
Reference current	: 1, 5, 10, 15 and 20 A
Destined for the measurement of	: electrical energy, in a - three-phase four-wire network - three-phase three-wire network - two-phase three-wire network - single-phase two-wire network
Accuracy class	: A or B or C
Environment classes	: M2 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12090 revision 3;
- Documentation folder T12090-4.

Valid until 21 June 2031

Remarks This revision replaces the earlier versions including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
15 November 2022

Certification Board