

Issued by NMI Certin B.V.,
 designated and notified by the Netherlands to perform tasks with respect to
 conformity assessment procedures mentioned in article 17 of Directive
 2014/32/EU, after having established that the Measuring instrument meets
 the applicable requirements of Directive 2014/32/EU, to:

Manufacturer EMH metering GmbH & Co. KG
 Neu-Galliner Weg 1
 19258 Gallin
 Germany

Measuring instrument A static **Active Electrical Energy Meter**
 Type : LZQJ-SGM
 Manufacturer's mark or name : EMH
 Reference voltage : 3x57,7/100 V ... 3x240/415 V
 3x220/380 V...3x240/415 V
 3x100 V... 3x415 V
 Reference current : 1 A or 5 A
 Destined for the measurement of : electrical energy, in a
 - three-phase four-wire network
 - three-phase three-wire network
 - single-phase two-wire network
 - M1 – M8 connection types
 according to DIN 43856

Accuracy class : A or B or C
 Environment classes : M1 / E2
 Temperature range : -25 °C / +55 °C

Further properties are described in the annexes;
 – Description T12144 revision 4;
 – Documentation folder T12144-4.

Valid until 26 October 2031

Initially issued 26 October 2021

Remark This revision replaces the earlier versions, including the documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
 31 January 2024

Certification Board