

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the Measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Networked Energy Services  
780 Montague Expressway, Suite 401  
San Jose, California 95131  
United States of America

Measuring instrument A static **Active Electrical Energy Meter**  
Type : Direct Connected Meter (DCM)  
83335-3xxxxxx, 85335-3xxxxxx  
Transformer Connected Meter (TCM)  
83535-3xxxxxx, 85535-3xxxxxx

Reference voltage : 3x110/190 V ... 3x240/415 V  
2x110 V ... 2x240 V  
110 V ... 240 V

Reference current : 5 A (TCM)  
5 A, 10A, 20 A (DCM)

Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- two-phase three-wire network  
- single-phase two-wire network

Accuracy class : A or B (DCM)  
B or C (TCM)

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12242 revision 0;
- Documentation folder T12242-1.

Valid until 14 March 2033

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
14 March 2023

## Certification Board

**NMI Certin B.V.**  
Thijssseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMI Certin B.V. as Notified  
Body can be verified at [http://  
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.