

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the Measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Meter&Control  
Veljka Dugoševića 54  
Belgrade  
Serbia

Measuring instrument A static **Active Electrical Energy Meter**

Type	:	F2-TD
Manufacturer's mark or name	:	Meter&Control
Reference voltage	:	3x230/400 V
Reference current	:	5 A
Destined for the measurement of	:	electrical energy, in a - three-phase four-wire network
Accuracy class	:	A or B
Environment classes	:	M1 / E2
Temperature range	:	-40 °C / +70 °C

Further properties are described in the annexes:

- Description T12562 revision 2;
- Documentation folder T12562-2.

Valid until 14 April 2033

Initially issued 14 April 2023

Remark This revision replaces the earlier versions, excluding its  
documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
20 October 2023

## Certification Board