

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Itron  
1 Avenue des temps modernes  
ZI du Bernais B.P. 23  
86361 Chasseneuil du Poitou  
France

Measuring instrument A static **Active Electrical Energy Meter**

Type : ACE663B  
Manufacturer's mark or name : Itron  
Reference voltage : 3x230/400 V  
Reference current : 1; 1,5; 2,5 or 5 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
Accuracy class : B or C  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes  
– Description T10216 revision 14  
– Documentation folder T10216-4

Valid until 25 May 2029

Initially issued 15 June 2009

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
14 June 2024

Certification Board