

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer SAGEMCOM ENERGY & TELECOM SAS  
4 ALLEE DES MESSAGERIES  
92270 BOIS-COLOMBES  
France

Measuring instrument A static **Active Electrical Energy Meter**

Type : CX1000-6 SL (CX1000-6 EDP STREETLIGHTING) and CX1000-6 S

Manufacturer's mark or name : SAGEMCOM ENERGY & TELECOM SAS

Reference voltage : 127 V or 230 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10329 revision 19;
- Documentation folder T10329-8.

Valid until 29 November 2030

Initially issued 29 November 2010

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
4 March 2025

Certification Board