

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Kamstrup A/S
Industrivej 28, Stilling
DK-8660 Skanderborg
Denmark

Measuring instrument A static **Active Electrical Energy Meter**

Type : 685-2xx (Kamstrup 251Cx5)
685-3xx (Kamstrup 351Cx5)
685-4xx (Kamstrup 451Cx5)
685-11x-xx-D-x (OMNIPOWER CT var 1 and var 2)

Manufacturer's mark or name : Kamstrup

Reference voltage : 3x230/400V or 3x230V

Reference current : 1 A or 5A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network

Accuracy class : B or C

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10542 revision 64;
- Documentation folder T10542-8.

Valid until 15 March 2033

Initially issued 15 March 2013

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
11 April 2025

Certification Board