





Number T10678 revision 12 Project number 3978724 Page 1 of 1

Issued by NMi Certin B.V.,

> designated and notified by the Netherlands to perform tasks with respect to conformity asssessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets

the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Inepro Metering BV

Pondweg 7

2153 PK Nieuw Vennep

The Netherlands

Measuring instrument A static Active Electrical Energy Meter

Type **PRO380**

Manufacturer's mark or name Inepro

Reference voltage 3x230/400 V

Reference current : 1.5 A

Destined for the measurement of electrical energy, in a

> - three-phase four-wire network - three-phase three-wire network - single-phase two-wire network

Accuracy class B or C

Environment classes M1 / E2

: -25 °C / +70 °C Temperature range

Further properties are described in the annexes:

- Description T10678 revision 12;

- Documentation folder T10678-7.

Valid until 9 December 2034

Initially issued 9 December 2014

This revision replaces the earlier versions, except for its documentation

folder.

Issuing Authority

Remark

NMi Certin B.V., Notified Body number 0122 30 June 2025

Certification Board

NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete document only is permitted.

the top of the electronic version of this certificate.





This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at