

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Networked Energy Services
5215 Hellyer Avenue, Suite 150
San Jose, CA 95138
United States of America

Measuring instrument A static **Active Electrical Energy Meter**

Type : 83334-1XXXXX, 83344-1XXXXX,
84334-1XXXXX, 84344-1XXXXX

Manufacturer's mark or name : Networked Energy Services (NES)

Reference voltage : 120 V ... 240 V

Reference current : 5 A, 10 A or 20 A

Destined for the measurement of : electrical energy, in a
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T10701 revision 21;
- Documentation folder T10701-8.

Valid until 15 July 2035

Initially issued 15 July 2015

Remarks This revision replaces the earlier versions, except for the documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
15 July 2025

Certification Board