



EU-type examination certificate

Number **T10826** revision 33
Project number 3909948
Page 1 of 1

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the Measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Gridspertise S.r.L
Via Ombrone, 2
00198 Roma
Italy

Measuring instrument A static **Active Electrical Energy Meter**
Type : GEMIS
Manufacturer's mark or name : Gridspertise S.r.L
Reference voltage : 230 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : B or A
Environment classes : M1 / E2
Temperature range : -25 °C / +55 °C
IP rating : IP 54

Further properties are described in the annexes:
- Description T10826 revision 33;
- Documentation folder T10826-15.

Valid until 1 September 2026

Initially issued 1 September 2016

Remark This revision replaces the earlier versions, including its documentation
folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
1 August 2025

Certification Board

NMI Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMI Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

