

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis + Gyr A.E.  
78th km National Road Athens-Corinth  
GR-201 00, Corinth  
Greece

Measuring instrument A static **Active Electrical Energy Meter**

Type : E450 G3 IDIS (ZxXi3x0xQ S4)

Manufacturer's mark or name : Landis + Gyr

Reference voltage : 3x220/380 V ... 3x240/415 V  
3x220 V ... 3x240 V

Reference current : 5 A or 10 A

Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- three-phase three-wire network  
- two-phase three-wire network  
- single-phase two-wire network

Accuracy class : B or A

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11170 revision 12;
- Documentation folder T11170-5.

Valid until 1 September 2027

Initially issued 1 September 2017

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
23 April 2025

Certification Board