

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Klefr  
Pondweg 7  
2153 PK Nieuw Vennep  
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type	:	6931, 6933, 6934
Manufacturer's mark or name	:	Klefr
Reference voltage	:	3x230/400 V
Reference current	:	5 A
Destined for the measurement of	:	electrical energy, in a - three-phase four-wire network - three-phase three-wire network - single-phase two-wire network
Accuracy class	:	B
Environment classes	:	M1 / E2
Temperature range	:	-40 °C / +70 °C

Further properties are described in the annexes:  
– Description T11175 revision 3;  
– Documentation folder T11175-3.

Valid until 1 September 2027

Initially issued 1 September 2017

Remark This revision replaces the earlier versions, excluding for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
24 September 2024

Certification Board