

Issued by NMI Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr AG
 Alte Steinhauserstrasse 18
 CH-6330 Cham
 Switzerland

Measuring instrument A static **Active Electrical Energy Meter**

Type : E570 S2 ZxY4xxCQ...S2 (G3-PLC) or ZxY4xxCW1...S2 (P2P 2G/4G)

Manufacturer's mark or name : Landis+Gyr

Reference voltage : ZxY4xxCQ...S2 (G3-PLC)
 ZMY 3x220/380V – 3x240/415V
 ZFY 3x220V – 3x240V
 ZxY4xxCW1...S2 (P2P 2G/4G)
 ZMY 3x58/100V - 3x277/480V
 ZFY 3x100V – 3x240V

Reference current : 1 A or 5 A

Destined for the measurement of : electrical energy, in a
 - single-phase two-wire network
 - two-phase three-wire network
 - three-phase three-wire network
 - three-phase four-wire network

Accuracy class : B or C

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
 – Description T11335 revision 13;
 – Documentation folder T11335-5.

Valid until 8 August 2028

Initially issued 8 August 2018

Remark This revision replaces the earlier versions, excluding its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
 17 June 2025

Certification Board