

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer ALLEGRA Trocknungstechnik Vertriebs GmbH
Berliner Allee 303
D-13088 Berlin
Germany

Measuring instrument A static **Active Electrical Energy Meter**

Type	: PH10; PH20
Manufacturer's mark or name	: Allegra
Reference voltage	: 230 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M1 / E2
Temperature range	: -25 °C / +55 °C

Further properties are described in the annexes:
– Description T11594 revision 2;
– Documentation folder T11594-3.

Initial issue 27 August 2019

Valid until 27 August 2029

Remark This revision replaces the previous versions, including its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
19 November 2024

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon on top of the electronic version of this certificate.

Reproduction of the complete document only is permitted.