

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer I.C.Y. B.V.
Houtsaachmole 35
8531 WC Lemmer
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : ICY4850CM
Manufacturer's mark or name : I.C.Y.
Reference voltage : 230 V
Reference current : 3 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : B
Environment classes : M1 / E2
Temperature range : -25°C to +55°C

Further properties are described in the annexes:
- Description T11823 revision 1;
- Documentation folder T11823-2.

Valid until 14 October 2031

Initially issued 14 October 2021

Remark This revision replaces the earlier version, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
15 May 2025

Certification Board