

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr AG
Alte Steinhauserstrasse 18
CH-6330 Cham
Switzerland

Measuring instrument A static **Active Electrical Energy Meter**

Type : E660-A...S1 and E660-A...S2
Manufacturer's mark or name : Landis+Gyr
Reference voltage : 3x58/100V - 3x240/415V - 3x277/480V
(3p/4w)
3x100V – 3x480V (3p/3w)
Reference current : 1 or 5 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network
Accuracy class : B or C
Environment classes : M2 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes
– Description T11845 revision 13
– Documentation folder T11845-6

Valid until 18 June 2030

Initially issued 18 June 2020

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
31 January 2025

Certification Board