

EU-type examination certificate

Number **T11845** revision 14
Project number 3936955
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect
to conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Landis+Gyr AG
Alte Steinhäuserstrasse 18
CH-6330 Cham
Switzerland

Measuring instrument A static **Active Electrical Energy Meter**

Type : E660-A...S1 and E660-A...S2
Manufacturer's mark or name : Landis+Gyr
Reference voltage : 3x58/100V - 3x240/415V - 3x277/480V
(3p/4w)
3x100V – 3x480V (3p/3w)
Reference current : 1 or 5 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network
Accuracy class : B or C
Environment classes : M2 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11845 revision 14;
- Documentation folder T11845-7.

Valid until

18 June 2030

Initially issued

18 June 2020

Remark

This revision replaces the earlier versions, including its documentation
folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
4 July 2025

Certification Board