

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr AG
Alte Steinhauserstrasse 18
CH-6330 Cham
Switzerland

Measuring instrument A static **Active Electrical Energy Meter**
Type : E660-A...S1 and E660-A...S2

Manufacturer's mark or name : Landis+Gyr

Reference voltage : 3x58/100V - 3x240/415V -
3x277/480V (3p/4w)
3x100V - 3x480V (3p/3w)

Reference current : 1 or 5 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T11845 revision 9;
- Documentation folder T11845-4.

Valid until 18 June 2030

Initially issued 18 June 2020

Remark This revision replaces the earlier revisions, excluding its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
01 March 2024

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.