

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Apator S.A.  
ul. Gdańska 4a, lok C4  
87-100 Toruń  
Poland

Measuring instrument A static **Active Electrical Energy Meter**

Type : PICUS+ or PICUS  
Manufacturer's mark or name : Apator S.A.  
Reference voltage : 3x230/400 V or 230 V  
Reference current : 5 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C or -25 °C / +55 °C

Further properties are described in the annexes:  
- Description T11887 revision 4;  
- Documentation folder T11887-5.

Valid until 29 October 2030

Initially issued 29 October 2020

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
15 October 2024

Certification Board