

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Landis+Gyr
78 km National Road Athens
Corinth GR-20100
Greece

Authorized representative

Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument

A static poly phase electricity meter

Type : E360-AM3D...S2
E360-AM3D...s2

Manufacturer's mark or name : Landis+Gyr

Reference voltage : 230V; 2-3x230/400V

Reference current : 5 A or 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12072 revision 19;
- Documentation folder T12072-9.

Valid until

29 June 2031

Initially issued

29 June 2021

Remark

This revision replaces the earlier versions, including its documentation folder

Issuing Authority

NMi Certin B.V., Notified Body number 0122
9 January 2025

Certification Board