				e
	N Mİ	Ευ-τγρ	e	examination certificate
				Number T12314 revision 3 Project number 3937318 Page 1 of 1
ŧ	Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity asssessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:		
	Manufacturer	Schneider Electric 35 rue Joseph Monier 92500 Rueil Malmaison France		
	Measuring instrument A static Active Electrical Energy Meter		ter	
		Туре	:	iEM2435 / iEM2455
		Manufacturer's mark or name	:	Schneider Electric
		Reference voltage	:	230 V
		Reference current	:	5 A
		Destined for the measurement of	:	electrical energy, in a - single-phase two-wire network
		Accuracy class	:	A or B
		Environment classes	:	M1 / E2
		Temperature range	:	-40 °C / +70 °C
		Further properties are described in – Description T12314 revision 3; – Documentation folder T12314-3.		e annexes:
	Valid until	12 April 2032		
	Initially issued	12 April 2022		
	Remark	This revision replaces the earlier versions, including its documentation folder.		



NMi Certin B.V., Notified Body number 0122 21 July 2025

Certification Board

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/ Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.



NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl