

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Schneider Electric
35 rue Joseph Monier
92500 Rueil Malmaison
France

Measuring instrument A static **Active Electrical Energy Meter**

Type : iEM2435 / iEM2455/ EM2214

Manufacturer's mark or name : Schneider Electric

Reference voltage : 230 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T12314 revision 4;
- Documentation folder T12314-4.

Valid until 12 April 2032

Initially issued 12 April 2022

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
16 April 2026

Certification Board