

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Kamstrup A/S
Industrivej 28, Stilling
DK-8660 Skanderborg
Denmark

Measuring instrument A static **Active Electrical Energy Meter**

Type : OMNIA e-meter CT

Manufacturer's mark or name : Kamstrup

Reference voltage : 3x230/400V and 3x240/415V

Reference current : 1 A and 5 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : A or B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T12339 revision 12;
- Documentation folder T12339-4.

Valid until 23 February 2032

Initially issued 23 February 2022

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
23 April 2026

Certification Board