

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Kamstrup A/S  
Industrivej 28, Stilling  
DK-8660 Skanderborg  
Denmark

Measuring instrument A static **Active Electrical Energy Meter**

Type : OMNIA e-meter CT  
Manufacturer's mark or name : Kamstrup  
Reference voltage : 3x230/400V and 3x240/415V  
Reference current : 1 A and 5 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
Accuracy class : A or B or C  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C  
Further properties are described in the annexes  
- Description T12339 revision 8  
- Documentation folder T12339-3

Valid until 23 February 2032

Initially issued 23 February 2022

Remarks This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
11 July 2024

Certification Board