

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer JHB Energy B.V.  
Burgemeester Burgerslaan 40  
5245 NH Rosmalen  
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : IQ0304100b1 or IQ0304100f1

Manufacturer's mark or name : KWHIQ

Reference voltage : 3x230/400 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12399 revision 2;
- Documentation folder T12399-3.

Valid until 6 July 2032

Initially issued 7 July 2022

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
3 April 2025

Certification Board