

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the Measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer EDMI Limited  
47 Yishun Industrial Park A  
Singapore 768724

Measuring instrument A static **Active Electrical Energy Meter**

Type	: Mk7Mi
Manufacturer's mark or name	: EDMI Limited
Reference voltage	: 220-240 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: B or A
Environment classes	: M1 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12457 revision 1;
- Documentation folder T12457-2.

Valid until 22 August 2033

Initially issued 22 August 2023

Remark This revision replaces the earlier version(s), including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
17 January 2025

Certification Board