

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Meter&Control
Veljka Dugoševića 54
11050 Belgrade
Serbia

Measuring instrument A static **Active Electrical Energy Meter**

Type : F2-MD
Manufacturer's mark or name : Meter&Control
Reference voltage : 230 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T12711 revision 3;
- Documentation folder T12711-2.

Valid until 23 May 2034

Initially issued 23 May 2024

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
18 February 2025

Certification Board