

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Hausheld AG
Blumenberger Straße 143-145
41061 Mönchengladbach
Germany

Measuring instrument A static **Active Electrical Energy Meter**

Type : 3.HZ-B*-D*-*-**
3.HZ-B*-H*-*-**
e.HZ-BC-D*-*-**

Manufacturer's mark or name : Hausheld AG

Reference voltage : 3x230/400 V, 230 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -25 °C / +55 °C

Further properties are described in the annexes:

- Description T12751 revision 1;
- Documentation folder T12751-2.

Valid until 2 February 2034

Initially issued 2 February 2024

Remark This revision replaces the earlier version, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
11 October 2024

Certification Board