



EU-type examination certificate

Number **T12801** revision 4
Project number 4015423
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Zhejiang Eastron Electronic Co., Ltd.
No.52, Dongjin Road, Nanhu
Jiaxing, Zhejiang
China

Measuring instrument

A static **Active Electrical Energy Meter**

Type : SDM630

Manufacturer's mark or name : Eastron

Reference voltage : 3x230/400 V; 3x400 V; 230 V

Reference current : 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12801 revision 4;
- Documentation folder T12801-4.

Valid until

4 November 2034

Initially issued

4 November 2024

Remark

This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
2 December 2025

Certification Board

NMi Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that
no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)
ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

