

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Eastron Europe Limited
Suite 20 Cornwallis House, Howard Chase
Basildon SS14 3BB
United Kingdom

Authorised representative Eastron Europe Limited
Suite 20 Cornwallis House, Howard Chase
Basildon SS14 3BB
United Kingdom

Measuring instrument A static **Active Electrical Energy Meter**

Type : SDM630-CB

Manufacturer's mark or name : Eastron

Reference voltage : 3x230/400 V

Reference current : 10 A

Destined for the measurement of : electrical energy, in a
- single-phase three-wire network
- three-phase three-wire network
- three-phase four-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12829 revision 0;
- Documentation folder T12829-1.

Valid until 18 July 2034

Initially issued 18 July 2024

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
18 July 2024

Certification Board