

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Zhejiang Eastron Electronic Co., Ltd.
No.52, Dongjin Road, Nanhu
Jiaxing, Zhejiang
China

Measuring instrument A static **Active Electrical Energy Meter**

Type : SDM72
Manufacturer's mark or name : Eastron
Reference voltage : 3x230/400 V; 230 V
Reference current : 10 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- single-phase two-wire network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes
- Description T12831 revision 1
- Documentation folder T12831-2

Valid until 2 December 2034

Initially issued 2 December 2024

Remark This version replaces the earlier version including the documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
20 December 2024

Certification Board