

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Controlin
Glasblazerstraat 1
2984 BL Ridderkerk
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : SKD-103-M V1, SKD-103-ME

Manufacturer's mark or name : Controlin

Reference voltage : 3x230/400 V; 3x400 V; 230 V

Reference current : 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes

- Description T12850 revision 1
- Documentation folder T12850-2

Valid until 22 November 2034

Initially issued 22 November 2024

Remarks This revision replaces the earlier version, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
25 April 2025

Certification Board