

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Controlin  
Glasblazerstraat 1  
2984 BL Ridderkerk  
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : SKD-103-M V1, SKD-103-ME  
Manufacturer's mark or name : Controlin  
Reference voltage : 3x230/400 V; 3x400 V; 230 V  
Reference current : 10 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- three-phase three-wire network  
- single-phase two-wire network

Accuracy class : B or C  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T12850 revision 1;  
- Documentation folder T12850-2.

Valid until 22 November 2034

Initially issued 22 November 2024

Remark This revision replaces the earlier version, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
23 May 2025

Certification Board